



8813 Highway 41 South - Riverview, Florida 33569  
 Telephone (813) 677-9111 - Telex 52666  
 FAX - Accounting (813) 671-6283

## CERTIFICATE OF ANALYSIS FLUOROSILIC ACID

Results of Analysis of a Weighted Average Sample

CAR NO: SHPX204519

Date: March 12, 2005

ANALYSIS	RESULT
NET H <sub>2</sub> SiF <sub>6</sub>	24.23 %
P <sub>2</sub> O <sub>5</sub>	0.06 %
FREE ACID*	0.54 %
DENSITY	1.219 g/ml
APHA	30
LEAD	< 1 ppm
ARSENIC	52.51 ppm
CHLORIDE	0.62 ppm

WE CERTIFY THAT PRODUCT SHIPPED WITH THIS CERTIFICATE OF ANALYSIS MEETS AWWA  
 STANDARD B703-97 AND ANS/NSF STANDARD 60 REQUIREMENTS

\* AWWA B-703-00



*David W. Averitt*

David Averitt / QC lab manager